



Post Hydrants shall be non-freezing, self draining type with a 5' bury. These hydrants will be furnished with a 2" FIP inlet, a non-turning operating rod, and shall open to the left. All of the working parts shall be of bronze-to-bronze design, and be servicable from above grade with no digging. The outlet shall also be bronze and be 2-1/2" NST. Hydrants shall be lockable to prevent unauthorized use as manufactured by Kupferle Foundry Co., St. Louis, MO, or approved equal.

THE CITY OF ROSENBERG, FORT BEND COUNTY, TEXAS
DEPARTMENT OF PUBLIC WORKS

MAINGUARD NO. 77
BLOW-OFF HYDRANT

DESIGN: CAK	CAD: STAFF	SCALE NTS	DATE: 02/11	DRAWING: W-102
----------------	---------------	--------------	----------------	-------------------