



NOTES:

1. TRACER WIRE FOR PVC PIPE SHALL BE NO. 10 AWG GAUGE COATED COPPER WIRE AND ALL SPLICES SHALL BE MADE WITH A MECHANICAL WATER PROOF CONNECTION.
2. TRACER WIRE SHALL COME UP AT THE LIFT STATION, AIR RELIEF VALVE LOCATIONS AND AT THE MANHOLE OR WETWELL AT THE FORCEMAIN POINT OF DISCHARGE.
3. TRACER WIRE MUST BE "DUCT" TAPED TO THE FORCEMAIN PIPE AT INTERVALS NOT TO EXCEED TEN (10)-FEET AND TAPE WRAPPED AROUND FORCEMAIN TWICE.

THE CITY OF ROSENBERG, FORT BEND COUNTY, TEXAS
DEPARTMENT OF PUBLIC WORKS

TRACER WIRE
FOR FORCEMAINS

DESIGN: CAK	CAD: STAFF	SCALE: NTS	DATE: 01/26	DRAWING: S-107
----------------	---------------	---------------	----------------	-------------------